

Annex 2

FOURTH SCHEDULE

[Regulation 4(2)(b)]

(Standard A)

The Malaysian Diesel Standards

(1) PROPERTIES	(2) EURO 4-M		(3) TEST METHOD
	MINIMUM	MAXIMUM	
Density @ 15°C, kg/l	0.810	0.870	MS 1893
Cetane Number	49	-	MS 1890
or Cetane Index	49	-	MS 1895
Distillation at 95 %, deg C	-	370	MS 563
Total Sulphur, mg/kg	-	50	MS 1891