

Annex 1

SECOND SCHEDULE

[Regulation 4(1)(b)]

(Standard B)

The Malaysian Diesel Standards

(1) PROPERTIES	(2) EURO 2-M		(3) TEST
	MINIMUM	MAXIMUM	METHOD
Density @ 15°C, kg/l	0.810	0.870	ASTM D 1298/ D 4052/
Cetane Number	49	-	ASTM D 613/ D 6890/ IP 498
or Cetane Index	49	-	ASTM D 976/ D 4737
Distillation at 95 %, deg C	-	370	ASTM D 86
Total Sulphur, mg/kg	-	500	ASTM D 4294/ D 2622/ D 5453/ IP 336